



GOVT OF KARNATAKA
**KARNATAKA FIRE & EMERGENCY
DEPARTMENT**

Ref : - 09/HPT/DFO/TFS/2024

Dated : 24/04/2024

:- FIRE SAFETY CERTIFICATE :-

M/s. Sri Raghavendra International School , C .R. Pharmacy College Campus,
Urdigere Main Road , Koratagere ,Tumkur district, Karnataka – 572129,
I inspected that they have installed portable fire extinguishers from fire safety
point of view . Each extinguisher is subjected to hydraulic pressure test under
300 pound pressure and inspected each extinguisher on 23/04/2024 for any
leakage and visible distortion and found all the extinguisher are in good
condition for use


This Hydraulic pressure test certificate will be valid for one year from
23/01/2024 to 22/04/2025

Certified Fire Extinguishers details are as below

S.N	TYPE OF EXTINGUISHER	RESULT
1	ABC Types Fire Extinguisher	In Good Working Condition
2	ABC Types Fire Extinguisher	In Good Working Condition
3	ABC Types Fire Extinguisher	In Good Working Condition
4	ABC Types Fire Extinguisher	In Good Working Condition
5	ABC Types Fire Extinguisher	In Good Working Condition
6	ABC Types Fire Extinguisher	In Good Working Condition

Note : Care & maintenance should be done as per the schedule

To
M/s. Sri Raghavendra Internatioanl School
C. R. Pharmacy College Campus
Urdigere Main Road
Koratagere
Tumkur ditrict
Karnataka-572129


District Fire Officer
Karnataka Fire & Emergency Services
Tumakuru-572103.